



2.0m x 43m pedestrian visibility splay is obstructed by the building, 1.5m x 43m is not obstructed.

Pedestrian visibility splays pass through a fenced area. This fencing will obstruct the required visibility splays. The fencing will require relocating behind the visibility splays, possibly requiring re-alignment of the existing brick wall (not shown on the topographical survey) - see photo.




KEY

- Driver visibility splay 2.4m x 43m to kerb edge
- Pedestrian visibility splays
 - - 1.5m x 43m to kerb edge
 - - 2.0m x 43m to kerb edge (Preferred)



© Copyright



YORK HOUSE
EDISON PARK
DORCAN WAY
SWINDON
WILTSHIRE
SN3 3RB
Tel : 01793 619965

Web Site www.ColeEasdon.com
E-mail cec@ColeEasdon.com

Client
Radley College

Job Title
**Proposed Development at Radley
Oxfordshire**

Drawing Title
**Alternative Church Road crossing point
arrangement / Relocation of
School Car Park Access**

Drawing Status

FOR COMMENT	FOR PLANNING	FOR TENDER	FOR APPROVAL	FOR CONSTRUCTION	AS BUILT
-------------	--------------	------------	--------------	------------------	----------

CONSTRUCTION AT CLIENT / CONTRACTOR RISK

Designed by: **PJS** Drawn by: **PJS** Checked by: **JBF**

Date: **January 2020** Scale: **1:250 (A2)**

Orig. No. **Plan 4407/216** Rev. **-**